



# COMMONWEALTH of VIRGINIA

Department of Health

DONALD R. STERN, M.D., M.P.H.  
ACTING STATE HEALTH COMMISSIONER

P. O. BOX 2448  
RICHMOND, VA 23218

June 8, 1995

**MEMORANDUM**

**GMP #70**

**TO:** District Directors  
Environmental Health Managers  
Environmental Health Supervisors  
Office of Environmental Health Staff  
Office of Water Programs

**FROM:** Donald J. Alexander, Director *Donald J. Alexander*  
Division of Onsite Sewage and Water Services

**SUBJECT:** Preliminary Approval of Sewage Discharge Systems  
Sewage - Discharge - Approval

Aquarobic USA has requested preliminary approval of the "AQUAROBIC: THE VIRGINIA 600 MINI-PLANT/FILTER". Based on a technical review of the design and engineering principles conducted by the Division in accordance with §2.25 B of the Alternative Discharging Regulations and the recommendations of the Discharge Regulations Task Force's Technical Committee, the Division of Onsite Sewage and Water Services grants **preliminary approval** as indicated in paragraph 1) and 3) of the attached letter. The approval becomes effective the date of this memorandum

GMP #70  
Sewage - Discharge - Approval  
*[Signature]*



# COMMONWEALTH of VIRGINIA

## Department of Health

DONALD R. STERN, M.D., M.P.H.  
ACTING STATE HEALTH COMMISSIONER

P. O. BOX 2448  
RICHMOND, VA 23218

June 8, 1995

Daniel E. Pavón, President  
AQUAROBIC International, Inc.  
999A Shenandoah Shores Road  
Front Royal, Virginia 22630

Dear Mr. Pavón:

Re: Request for preliminary approvals of "AQUAROBIC: THE VIRGINIA 600 MINI-PLANT/FILTER" under the Alternative Discharging Sewage Treatment Regulations for Single Family Dwellings (DSTR).

The Division of Onsite Sewage and Water Services has reviewed your request for preliminary approval of the Virginia 600 Mini-Plant as referenced in our letter to you dated March 15, 1995. Based on our review we find the following:

- 1) Preliminary approval is granted to the Virginia 600 Mini-Plant/Filter (mini-plant), as shown in attachment 1, for discharges to dry ditch or intermittent streams of 500' or more (IS/DD 500) for design flows up to 600 gpd. This sewage treatment system consists of a 6' wide by 11' long by 4' deep aerobic batch activated sludge compartment which receives the waste directly from the house connection. Clarified wastewater from the aeration chamber is then pumped to a 3' wide by 6' long by 3.6' deep up flow gravel filter. The gravel in the filter will have an effective size of less than 3.5 mm and a uniformity coefficient of less than 4.0. Virginia Department of Transportation's 78, 8 or 9 gravel should meet the effective size and uniformity coefficient. A pump is provided to return the liquid and any solids that accumulated in the filter back to the aeration chamber. Wastewater from the up flow filter passes through a tablet chlorinator and then enters the chlorine contact tank. The chlorine contact tank has an approximate volume of 600 gallons. Chlorinated wastewater then passes through a tablet dechlorinator. If ultraviolet light disinfection is used then the flow from the upflow filter must be limited to the capacity for the ultraviolet unit.


Daniel E. Pavón  
June 8, 1995  
page 2

- 2) Preliminary approval is denied for the unit described above for use in discharges to dry ditches or intermittent streams 250'-499' (IS/DD 250) in length. Based on your request the unit described above is not equivalent to the combination process (or redundant units) required in Table 3.2 of the Discharge Regulations. We do not think the upflow unit by itself (without the aeration unit) would be able to provide an effluent of 30 mg/L BOD<sub>5</sub> and 30 mg/L total Suspended solids.
- 3) Preliminary approval is granted to the Virginia 600 mini-plant/filter, as described in 1) above, with a constructed wetlands for discharges to IS/DD 250. This system is shown in attachment 2. The wetlands must be a minimum of 100 ft<sup>2</sup>. The components of the wetlands may be adjusted as new developments in wetlands treatment technologies progresses.
- 4) Preliminary approval is denied for the Virginia 600 mini-plant/filter when followed by a downflow sandfilter for discharges to IS/DD 250 as shown on pages 7 and 8 as attached to our letter dated March 15, 1995. This system has not been installed or tested to see if it will mechanically function as designed. If a bench scale or field experimental operation indicates the system will function as well as the system described in paragraph C and D of GMP #18, we may reevaluate your request.

Construction plans and specifications prepared by an engineer licensed in the Commonwealth of Virginia must be submitted, for the systems granted preliminary approval, and be in accordance with § 2.14 of DSTR. As appropriate all pumps must have either high water or failure to pump alarms. All chlorination and dechlorination tubes should be designed so that when the tubes are removed the tablets remain in the tube for inspection. Post aeration will need to be provided.

If you have any questions or comments on the above, please contact me at (804) 786-1750.

Sincerely,



Roger A. Cooley  
Assistant Technical Services Chief  
Division of Onsite Sewage and Water  
Services

pc: Don Alexander  
Cal Sawyer, PE

# STATE DEPARTMENT OF HEALTH

Richmond, Virginia



## Inter-Office Correspondence

June 20, 1995

### MEMORANDUM


TO: District Directors  
Environmental Health Managers  
Environmental Health Supervisors  
Office of Environmental Health Staff  
Office of ~~Water~~ Programs

FROM: Roger A. Cooley, Asst. Technical Services Chief  
Division of Onsite Sewage and Water Services



SUBJECT: GMP #70

Please attach the following drawings to GMP #70. These drawings may not have been mailed out with the GMP #70. I am Sorry for any inconvenience.

Attachments



PLAN VIEW




**N.S.F. INT. CLASS # 1  
AQUAROBIC CLASS # 1A  
WITH FILTER # 3,000**

REMOVAL EFFICIENCIES  
BASED ON AVERAGE OF VALUES  
9 DEC 1990 -- 4 JULY 1990

	INFLUENT AVERAGE	EFFLUENT AVERAGE	REDUCTION	PERCENT REDUCTION
BIOCHEMICAL OXYGEN DEMAND MG/L	150	5	145	96.6 %
SUSPENDED SOLIDS MG/L	180	5	175	97.2 %

© AQUAROBIC INT 1995



SECTION A - A

REVISED	BY
4-25-1991	D.E.P.
4-25-1991	D.E.P.
6-15-1992	D.E.P.
3-11-1995	D.E.P.



**AQUAROBIC**<sup>®</sup>  
INTERNATIONAL INC.

999A SHENANDOAH SHORES RD.  
FRONT ROYAL, VIRGINIA U.S.A. 22630  
PHONE: (703) 635-5200 / FAX: (703) 635-2177

SCALE: N.T.S.


MODEL # 954291-66 N. # 230 V

**THE VIRGINIA 600 MINI-PLANT / FILTER  
AND DISINFECTION IN FIBERGLASS TANK**




1

CONCEPT HEREIN DISCLOSED IS PROPRIETARY WITH AQUAROBIC LIMITED  
MAY NOT BE REPRODUCED OR USED WITHOUT PRIOR WRITTEN AUTHORIZATION.

- 1 SWITCH - LOW WATER PUMP SHUT OFF (NORMALLY OPEN)
- 2 SWITCH - HIGH WATER ALARM (NORMALLY OPEN)
- 3 SWITCH - EMERGENCY TRANSFER PUMP ON (NORMALLY OPEN)
- 4 SWITCH - PREVENTS FILTER BACK-WASH PUMP FROM RUNNING DURING EMERGENCY PUMPING (NORMALLY CLOSED)



**PLAN VIEW**



**SECTION A - A**

**N.S.F. INT. CLASS # 1  
AQUAROBIC CLASS # 1A  
WITH FILTER # 3,000**

REMOVAL EFFICIENCIES  
BASED ON AVERAGE OF VALUES  
9 DEC 1990 - 4 JULY 1990

	INFLUENT AVERAGE	EFFLUENT AVERAGE	REDUCTION	PERCENT REDUCTION
BIOCHEMICAL OXYGEN DEMAND MG/L	150	5	145	96.6 %
SUSPENDED SOLIDS MG/L	180	5	175	97.2 %

© AQUAROBIC INT. 1995

- NOTES:**
1. THE CONCEPT HEREIN DISCLOSED IS PROPRIETARY WITH AQUAROBIC INTERNATIONAL INC. AND MAY NOT BE REPRODUCED OR USED WITHOUT PRIOR WRITTEN AUTHORIZATION.
  2. FLS-1 SWITCH = LOW WATER PUMP SHUT OFF (NORMALLY OPEN)
  3. FLS-2 SWITCH = HIGH WATER ALARM (NORMALLY OPEN)
  4. FLS-3 SWITCH = EMERGENCY TRANSFER PUMP ON (NORMALLY OPEN)
  5. FLS-4 SWITCH = PREVENTS FILTER BACK-WASH PUMP FROM RUNNING DURING EMERGENCY PUMPING. (NORMALLY CLOSED)


REVISED	BY
4-28-1991	D.E.P.
4-27-1992	D.E.P.
6-15-1992	D.E.P.
3-11-1995	D.E.P.

**AQUAROBIC<sup>®</sup>**  
INTERNATIONAL INC.  
999A SHENANDOAH SHORES RD.  
FRONT ROYAL, VIRGINIA U.S.A. 22630  
PHONE: (703) 635-5200 / FAX: (703) 635-2277


SCALE: N.T.S. MODEL # F64291-6-S #230 V BY: D.L. PAYTON  
**THE VIRGINIA 600 MINI-PLANT / FILTER AND DISINFECTION IN FIBERGLASS TANK**  
DRAWING NO: V-600-230 VOLTS DATE: 6/15/1992

2





PLAN VIEW



SECTION A - A

NOTES:

1. THE CONCEPT HEREIN DISCLOSED IS PROPRIETARY WITH AQUAROBIC INTERNATIONAL INC. AND MAY NOT BE REPRODUCED OR USED WITHOUT PRIOR WRITTEN AUTHORIZATION.
2. FLS-1 SWITCH - LOW WATER PUMP SHUT OFF (NORMALLY OPEN)
3. FLS-2 SWITCH - HIGH WATER ALARM (NORMALLY OPEN)
4. FLS-3 SWITCH - EMERGENCY TRANSFER PUMP ON (NORMALLY OPEN)
5. FLS-4 SWITCH - PREVENTS FILTER BACK-WASH PUMP FROM RUNNING DURING EMERGENCY PUMPING. (NORMALLY CLOSED)

© AQUAROBIC INT 1994

**N.S.F. INT. CLASS # 1  
WITHOUT FILTER # 3,000**

REMOVAL EFFICIENCIES  
BASED ON AVERAGE OF VALUES  
11 APRIL 1993 -- 28 OCTOBER 1993

	INFLUENT MEDIAN	EFFLUENT MEDIAN	REDUCTION	PERCENT REDUCTION
BIOCHEMICAL OXYGEN DEMAND MGL	170	7	163	95.8%
SUSPENDED SOLIDS MGL	200	11	189	94.5%

**N.S.F. INT. CLASS # 1  
AQUAROBIC CLASS # 1 A  
WITH FILTER # 3,000**

REMOVAL EFFICIENCIES  
BASED ON AVERAGE OF VALUES  
9 DEC 1990 -- 4 JULY 1990

	INFLUENT MEDIAN	EFFLUENT MEDIAN	REDUCTION	PERCENT REDUCTION
BIOCHEMICAL OXYGEN DEMAND MGL	150	5	145	96.6%
SUSPENDED SOLIDS MGL	180	5	175	97.2%



**AQUAROBIC<sup>®</sup>  
INTERNATIONAL INC.**

999A SHENANDOAH SHORES RD.  
FRONT ROYAL, VIRGINIA U.S.A. 22630  
PHONE: (703) 635-5200 / FAX: (703) 635-2277

SCALE: N.T.S. MODEL # F54291-7.5-B \*230 V BY: D.E.P.A.V.O.N

THE MINI-PLANT # F54291-7.5 - 750 GAL/DAY  
FILTER UNIT DISCHARGING TO A  
CONSTRUCTED WETLAND WITH DISINFECTION  
IN FIBERGLASS TANKS FOR PARCEL 12A,  
FOREST HILLS ESTATES, PRINCE WILLIAM  
COUNTY, VIRGINIA.


DRAWING NO: V-750-230 VOLTS

DATE: 12/11/94


(6)

CONSTRUCTED WETLAND = 6' X 20' X 24" = 5 BEDROOMS BASED UPON GMP # 18 BY DON ALEXANDER - VIRGINIA DEP. OF HEALTH DATED: MARCH 2, 1993

CHLORINA ATTACHMENT 2 Cont.



PLAN VIEW



SECTION A - A

- NOTES:
1. THE CONCEPT HEREIN DISCLOSED IS PROPRIETARY WITH AQUAROBIC INTERNATIONAL INC. AND MAY NOT BE REPRODUCED OR USED WITHOUT PRIOR WRITTEN AUTHORIZATION.
  2. FLS-1 SWITCH = LOW WATER PUMP SHUT OFF (NORMALLY OPEN)
  3. FLS-2 SWITCH = HIGH WATER ALARM (NORMALLY OPEN)
  4. FLS-3 SWITCH = EMERGENCY TRANSFER PUMP ON. (NORMALLY OPEN)
  5. FLS-4 SWITCH = PREVENTS FILTER BACK-WASH PUMP FROM RUNNING DURING EMERGENCY PUMPING. (NORMALLY CLOSED)



**N.S.F. INT. CLASS # 1 WITHOUT FILTER # 3,000**

REMOVAL EFFICIENCIES BASED ON AVERAGE OF VALUES 11 APRIL 1993 -- 28 OCTOBER 1993

	INFLUENT MEDIAN	EFFLUENT MEDIAN	REDUCTION	PERCENT REDUCTION
BIOCHEMICAL OXYGEN DEMAND MGL	170	7	163	95.8%
SUSPENDED SOLIDS MGL	200	11	189	94.5%

**N.S.F. INT. CLASS # 1 AQUAROBIC CLASS # 1 A WITH FILTER # 3,000**

REMOVAL EFFICIENCIES BASED ON AVERAGE OF VALUES 9 DEC 1990 -- 4 JULY 1990

	INFLUENT MEDIAN	EFFLUENT MEDIAN	REDUCTION	PERCENT REDUCTION
BIOCHEMICAL OXYGEN DEMAND MGL	150	5	145	96.6%
SUSPENDED SOLIDS MGL	180	5	175	97.2%

**AQUAROBIC**®  
INTERNATIONAL INC.

999A SHENANDOAH SHORES RD.  
FRONT ROYAL, VIRGINIA U.S.A. 22630  
PHONE: (703) 636-5200 / FAX: (703) 636-5277

SCALE: N.T.S. MODEL #: F54291-7.5-B - 210 V BY: D.E.PAVON

**THE MINI-PLANT MODEL # F54291-7.5**  
**750 GAL/DAY FILTER UNIT DISCHARGING TO A CONSTRUCTED WETLAND WITH DISINFECTION IN FIBERGLASS TANKS**

DRAWING NO: 2-V-750-230 VOLTS DATE: 10/26/1994

