

DATE: May 29, 1992

TO: Office of Water Programs Engineers

THRU: Eric H. Bartsch, P.E., Director  
Office of Water Programs

FROM: Allen R. Hammer, P.E., Director  
Division of Water Supply Engineering

SUBJECT: Water - Design - Treatment - Fluoridation

Saturators for Fluoridation, a previous agreement made with the Division of Dental Health, allows certain design exceptions or provides clarifications for saturators as follows:

1. No separate room is required.
2. No scales/recorders are needed.
3. No dust collection equipment is needed.
4. Softening, if necessary, only the make-up water for the solution tank.
5. No need for two chemical pumps as fluoride is not needed to produce potable water.

TBG/edc