



COMMONWEALTH of VIRGINIA

Department of Health

P O BOX 2448
RICHMOND, VA 23218

TDD 1-800-828-1120

October 2, 2002

GMP #120

MEMORANDUM

TO: District Directors
Environmental Health Managers
Environmental Health Supervisors
Environmental Health Specialists

FROM: Anish R. Jantrania, Ph.D., P.E. 
Technical Services Engineer
Division of Onsite Sewage and Water Services

SUBJECT: Approval of Septic Tanks and Distribution Box Forms
Onsite - Product Approval - Septic Tanks and Distribution Box

The attached letters and the drawings are approval of septic tanks forms and distribution box forms as proposed by Winchester Building Supply Co., Inc. of Winchester, VA. Please add this memo and the attachments to your GMP Manual as GMP # 120.

Attachments

pc: Office of Environmental Health Service Staff

GMP #120

Onsite - Product Approval - Septic Tanks and Distribution Box.



COMMONWEALTH of VIRGINIA

Department of Health

P O BOX 2448

RICHMOND, VA 23218

TDD 1-800-828-1120

September 6, 2002

Mr. Richard Wilson
General Manager
Winchester Building Supply Co., Inc.
2001 Millwood Pike
Winchester, VA 22602

Dear Mr. Wilson:

I have reviewed the engineering drawings for septic tank forms you had submitted with your letter dated August 2, 2002. The drawings are for several different models for single and two-compartment Septic Tank (ST), "Advantax" Tank (AT) and for Grease Traps (GT). The tanks are either top seam (TS) or mid seam (MS). The models include ST-1500H-TS, ST-1500-TS, ST-1500-MS, ST-1250-MS, ST-1000-MS, ST-1000H-TS, ST-1000-TS, AT-1500H-TS, AT-1500-TS, AT-1000H-TS, AT-1000-TS, GT-1500H-TS, GT-1500-TS, GT-1000H-TS, and GT-1000-TS.

Section 12 VAC 5-610-815 of the Sewage Handling and Disposal Regulations (*Regulations*) specifies the design requirements for a septic tank. The information you have submitted for the above mentioned tanks appears to be in substantial compliance with the minimum requirements of the *Regulations*.

Please note that this approval is for forms only. You still must use adequate strength concrete and appropriate reinforcement material to make sure that the tanks are structurally sound. The tanks must also be properly installed and must have adequate inlet and outlet structures that comply with the current *Regulations*.

If you have any questions about this letter, you may call me at 804-225-4019.

Thank you,

Sincerely,

A handwritten signature in black ink, appearing to read "Anish R. Jantrania".

Anish R. Jantrania, Ph.D., P.E.
Technical Services Engineer.



COMMONWEALTH of VIRGINIA

Department of Health

P O BOX 2448
RICHMOND, VA 23218


TDD 1-800-828-1120

October 2, 2002

GMP #120

MEMORANDUM

TO: District Directors
Environmental Health Managers
Environmental Health Supervisors
Environmental Health Specialists

FROM: Anish R. Jantrania, Ph.D., P.E. 
Technical Services Engineer
Division of Onsite Sewage and Water Services

SUBJECT: Approval of Septic Tanks and Distribution Box Forms
Onsite – Product Approval – Septic Tanks and Distribution Box

The attached letters and the drawings are approval of septic tanks forms and distribution box forms as proposed by Winchester Building Supply Co., Inc. of Winchester, VA. Please add this memo and the attachments to your GMP Manual as GMP # 120.

Attachments

pc: Office of Environmental Health Service Staff

GMP #120
Onsite – Product Approval – Septic Tanks and Distribution Box.