

MEMORANDUM

Date: February 14, 2006

To: Environmental Health Managers
District Health Directors
VPI/SU Soil Scientists
Authorized Onsite Soil Evaluators
Professional Engineers

GMP #133

From: E. Thomas Joy, PE, Technical Services Engineer
Division of Onsite Sewage and Water Services

Subject: Approval of FRALO Plastech Mfg. SEPTECH™ Single-Compartment Septic Tanks Models ST-750 (with Effluent Filter), ST-1060, ST-1250, and ST-1500 for use in Virginia

Approval: The subject tanks do not meet all of the criteria of 12 VAC 5- 610-815 (the *Regulations*). However, after reviewing the data provided by FRALO Plastech Manufacturing, LLC, the Division of Onsite Sewage and Water Services finds the single-compartment SEPTECH™ septic tank models ST-1060, ST-1250, and ST-1500 substantially comply with the *Regulations* and are approved for use in Virginia without appurtenances. The single-compartment SEPTECH™ tank model ST-750 is approved for use in Virginia when an effluent filter is attached to the outlet structure upon installation. Any effluent filter used must be NSF certified. The tanks shall be installed and used in accordance with Virginia regulations and the manufacturer's instructions.