

STATE WATER CONTROL BOARD PAGE 1 OF 6
 9 VAC 25-720 - WATER QUALITY MANAGEMENT PLANNING REGULATIONS

9 VAC 25-720-130. New River.

A. Total maximum Daily Load (TMDLs)

TMDL #	Stream Name	TMDL Title	City/County	WBID	Pollutant	WLA	Units
1.	Stroubles Creek	Benthic TMDL for Stroubles Creek in Montgomery County, Virginia	Montgomery	N22R	Sediment	233.15	T/YR

~~B. Stream segment classifications, effluent limitations including water quality based effluent limitations, and waste load allocations.~~ B. Non - TMDL Waste Load Allocations.

STATE WATER CONTROL BOARD PAGE 2 OF 6
 9 VAC 25-720 - WATER QUALITY MANAGEMENT PLANNING REGULATIONS
 TABLE B1 - SEWERAGE SERVICE AREAS

Map ¹ No.	Locality	Receiving ² Stream Classification	NPDES Limits ³ Flow BOD ₅ -SS (mgd) (kg/day) (kg/day)			Status of Applicable ⁴ Section 201 Programs (January 1980)
	Abbs Valley	WQ	Permit not needed at present			Not on priority list
	Austinville	EL	Permit not needed at present			Not on priority list
	Bastian	EL	Permit not needed at present			Continue to use septic tanks for present
4	Blacksburg	EL	6.0	544.8	544.8	Completed
	Bland	EL	Permit to be issued in future			Not on priority list
29	Bluefield	WQ	3.5	406	406	Near Completion
	Boissevain	WQ	Effluent treated at Pocahontas			Redesign to treat at Pocahontas underway
2	Christiansburg	WQ	2.0	113.5	113.5	Completed
3	Dublin	EL	.22	29.9/49.9	29.9/49.9	To be connected to Pepper's Ferry STP (Radford Cluster) in FY-80
	Elk Creek	EL	Permit not needed at present			Continue to use septic tanks
4	Fairlawn	EL	.26	47	47	To be connected to Pepper's Ferry STP (Radford Cluster)
	Falls Mills	WQ	.144	5.5	5.5	Step I approved; limits for new plant
	Flat Ridge	EL	Permit not needed at present			Not on priority list
*5	Floyd	EL	.1	59.0	45.4	Small community; Step IV
13	Fries	EL	.02	11.8	9.1	Step I approved
14			.16	94.5	72.7	
17	Galax	EL	1.5	170	170	Not on priority list
	Glen Lyn	EL	Permit not needed at present			Not on priority list
15	Hillsville	EL	.2	23	23	Step I to be approved soon
16			.15	17	17	
*18	Independence	EL	.2	22.7	22.7	Step I approved; selected alternative was for one plant
19			.1	11.4	11.4	
	Ivanhoe	EL	Permit not needed at present			Continue to use septic tanks
	Max Meadows	EL	Permit to be issued in future			Not on priority list
	Mechanicsburg	EL	Permit not needed at present			Not on priority list
6	Narrows	EL	0.60	354.0	272.0	Step I at EPA; Step II - FY-80
	Newport	EL	Permit not needed at present			Not on priority list
7	Pearisburg	EL	0.30	177.0	136.0	Step I at EPA; Step II - FY-80; Step III - FY-84
	Pembroke	EL	Permit not needed at present			Not on priority list

9 VAC 25-720 - WATER QUALITY MANAGEMENT PLANNING REGULATIONS

*30	Pocahontas	WQ	.15	17	17	Step I grant approved to correct I/I problems
8	Pulaski	EL	2.0	234/303	234	To be connected to Pepper's Ferry STP (Radford Cluster) in FY 80 (Step II)
9	Radford STP	EL	2.5	1475	925	Step II - FY 80
*10	Rich Creek	EL	.12	71	54	Step I at EPA, Step IV - FY 83
31	Riner	EL	.035	4.0	4.0	Completed
	Rocky Gap	EL	Permit not needed at present			Continue to use septic tanks for present
12	Rural Retreat	EL	0.15	37.5	37.5	Step I to be completed in FY 80
	Speedwell	EL	Permit not needed at present			Continue to use individual septic tanks for present
	Troutdale	EL	Permit not needed at present			Continue to use individual septic tanks for present
	Woodlawn	EL	Permit to be issued in future			Not on priority list
11	Wytheville	EL	20	400	200	Sewage treatment plant completed

¹Discharges are shown on Plate 3.

²Effluent Limiting (E.L.) or Water Quality Limiting (WQ).

³For existing sewage treatment facility.

⁴For new sewage treatment facility.

*Small communities with combined Step II and III Grants.

STATE WATER CONTROL BOARD PAGE 4 OF 6
 9 VAC 25-720 - WATER QUALITY MANAGEMENT PLANNING REGULATIONS
 TABLE B2- EFFLUENT LIMITS⁽¹⁾⁽⁴⁾ NEW RIVER BASIN

Discharge	Receiving Stream	Maximum BOD ₅ Loading Limits (kg/day)
Troutdale	Fox Creek	6.1
Independence	Peachbottom Creek	13.5
Fries	New River	50.5
Galax	Chestnut Creek	240.3
Hillsville	Little Reed Island Creek	99.6
Woodlawn	Crooked Creek	69.5
Speedwell	Cripple Creek	17.4
Austinville	New River	19.5
Rural Retreat	South Fork	50.5
Wytheville	Reed Creek	298.3
Max Meadows	Reed Creek	82.4
⁽³⁾ Pulaski	Peak Creek	316.8
Floyd	Dodd Creek	24.1
Riner	Mill Creek	9.8
Blacksburg	New River	583.4
Christiansburg	Crab Creek	359.4
⁽³⁾ Dublin-New River-Fairlawn-Radford-Plum Creek	New River	772.7
Newport	Sinking Creek	2.9
Pembroke	New River	28.4
Bland	Walker Creek	10.3
Mechanicsburg	Walker Creek	3.1
Narrows-Pearisburg	New River	110.8
Bastian	Wolf Creek	10.4
Rocky Gap	Wolf Creek	9.0
Rich Creek	Rich Creek	19.9
Glen-Lyn	New River	5.7
Bluefield	Bluestone River	136.4
⁽²⁾ Abbs Valley	Laurel Fork	11.4
⁽²⁾ Pocahontas	Laurel Fork	5.5
⁽²⁾ Boisseevain	Laurel Fork	5.9

⁽¹⁾ Other effluent limitations will be determined by Water Quality Standards and/or Best Available Technology requirements.

⁽²⁾ Secondary treatment will be required until a further verification of the model is made to document the need for treatment beyond secondary.

⁽³⁾ To join Radford Cluster.

⁽⁴⁾ This table supersedes Table 152, page 199, Thompson & Litton, Inc., New River Basin Comprehensive Water Resources Plan, Volume V-A.

TABLE B3- NEW RIVER BASIN INDUSTRIAL EFFLUENT LIMITATIONS*

Parameters in Average kg/day or (Concentration) as mg/l

FACILITY NUMBER

9 VAC 25-720 - WATER QUALITY MANAGEMENT PLANNING REGULATIONS

MAP NUMBER 20-APCO 004 404 504 006	BOD ₅ 1.14	SS 382 1.14 318	OIL & GREASE 192 150	IRON (1.0) MAX	COPPER (1.0) MAX	
21 Burlington Industries 004	BOD ₅ 346	SS 354	PHENOLS 1.7	SULFIDE 0.9	ALUMINUM 1.0	
22 Colanese Fibers Co. 002 003	FLOW (MGD) 2.8 3.5	BOD ₅ (30) 2,999	SS 2,023	COD 27,694		
23 Hercules, Inc. 004	SS 34					
24 Lynchburg Foundry 004	SS 113	OIL & GREASE 53.1	PHENOLS 1.04			
25 RAAP Combined Ind. 026	FLOW (MGD) 1.0	BOD ₅ 114	SS 6,714 114	COD 237	OXIDIZED NITROGEN 18,697	SULFATE 565 67
26 New Jersey Zinc 004 002 003 004 005 006	BOD ₅ 2.3	SS (38) (.30) (20) (30) (30) 2.3	TOTAL CYANIDE (0.02) (0.02) (0.25)	DISSOLVED LEAD (0.25) (0.25) (0.35) (1.0) (0.25) -----	DISSOLVED ZINC (1.0) (1.0) (1.0) (0.25) (1.0) -----	DISSOLVED IRON (0.3) (0.25) (0.25) (0.25) -----
27 Elk Creek Raycart Products	SS (5)	OIL & GREASE (10)	IRON (1)	PHOSPHATE (2)	ZINC (0.5)	
28 Fields Mfg	BOD ₅ 3.6	SS 4.1	OIL & GREASE 0.8	TEMP. 75°F		

<u>Water Body</u>	<u>Permit No</u>	<u>Facility Name</u>	<u>Receiving Stream</u>	<u>River Mile</u>	<u>Outfall No.</u>	<u>Parameter Description</u>	<u>WLA</u>	<u>Units WLA</u>
VAS-N11R	VA0020281	Wytheville WWTP	Reed Creek	25.79	001	BOD5	360	KG/D

9 VAC 25-720 - WATER QUALITY MANAGEMENT PLANNING REGULATIONS

<u>Water Body</u>	<u>Permit No</u>	<u>Facility Name</u>	<u>Receiving Stream</u>	<u>River Mile</u>	<u>Outfall No.</u>	<u>Parameter Description</u>	<u>WLA</u>	<u>Units WLA</u>
VAS-N15R	VA0089443	Hillsville WWTP	Little Reed Island Creed	25.12	001	CBOD5, JAN-MAY	118	KG/D
						CBOD5, JUN-DEC	95	KG/D
VAW-N21R	VA0024040	Montgomery Co. PSA - Riner Town - Sewage Treatment Plant	Mill Creek	5.12	001	BOD5	7.5	KG/D
						TKN (N-KJEL)	1.9	KG/D
VAW-N22R	VA0060844	Blacksburg VPI Sanitation Auth - Lower Stroubles Creek WWTP	New River	71.37	001	BOD5	818	KG/D
VAS-N36R	VA0025054	Bluefield Westside WWTP	Bluestone River	25.64	001	BOD5, JUN-NOV	130	KG/D
						BOD5, DEC-MAY	260	KG/D
VAS-N36R	VA0062561	Tazewell County PSA - Falls Mills Hales Bottom STP	Bluestone River	22.49	001	BOD5	5.5	KG/D
VAS-N37R	VA0029602	Pocahontas STP	Laurel Fork	1.99	001	BOD5	17	KG/D
VAW-N21R	VA002040	MontgomeryCo.PSA - Riner Town - Sewage Treatment Plant	Mill Creek	5.12	001	BOD5	7.5	KG/D
						TKN (N-KJEL)		
VAW-N22R	VA0060844	Blacksburg VPI Sanitation Auth- Lower Stroubles Creek WWTP	New River	71.37	001	Bod 5	818	KG/D