

Amendments To Standards

■ OSHA amends Part 1915 of Title 29 of the Code of Federal Regulations as set forth below:

■ 1. The authority citation for Part 1915 continues to read as follows:

Authority: Sec. 41, Longshore and Harbor Workers' Compensation Act (33 U.S.C. 941); secs. 4, 6, and 8 of the Occupational Safety and Health Act of 1970 (29 U.S.C. 653, 655, 657); Secretary of Labor's Order No. 12-71 (36 FR 8754), 8-76 (41 FR 25059), 9-83 (48 FR 35736), 1-90 (55 FR 9033), 6-96 (62 FR 111), 3-2000 (65 FR 50017), or 5-2002 (67 FR 65008) as applicable; 29 CFR Part 1911.

■ 2. Amend § 1915.5 to revise paragraphs (d)(4)(i), (vi) through (x), and (xii) through (xviii) and by removing paragraph (d)(4)(xix) to read as follows:

§ 1915.5 Incorporation by reference.

* * * * *

(d) * * *

(4) * * *

(i) NFPA 1981-2002 Standard on Open-Circuit Self-Contained Breathing Apparatus for Fire and Emergency Services, IBR approved for 1915.505(e)(3)(v).

* * * * *

(vi) NFPA 10-2002 Standard for Portable Fire Extinguishers, IBR approved for §§ 1915.507(b)(1) and (b)(2).

(vii) NFPA 14-2003 Standard for the Installation of Standpipe and Hose Systems, IBR approved for §§ 1915.507(b)(2) and (d)(1).

(viii) NFPA 72-2002 National Fire Alarm Code, IBR approved for § 1915.507(c)(6).

(ix) NFPA 13-2002 Standard for the Installation of Sprinkler Systems, IBR approved for § 1915.507(d)(2).

(x) NFPA 750-2003 Standard on Water Mist Fire Protection Systems, IBR approved for § 1915.507(d)(2).

* * * * *

(xiii) NFPA 11-2005 Standard for Low-, Medium-, and High-Expansion

Foam, IBR approved for § 1915.507(d)(3).

(xiv) NFPA 17–2002, Standard for Dry Chemical Extinguishing Systems, IBR approved for § 1915.507(d)(4).

(xv) NFPA 12–2005, Standard on Carbon Dioxide Extinguishing Systems, IBR approved for § 1915.507(d)(5).

(xvi) NFPA 12A–2004, Standard on Halon 1301 Fire Extinguishing Systems, IBR approved for § 1915.507(d)(5).

(xvii) NFPA 2001–2004, Standard on Clean Agent Fire Extinguishing Systems, IBR approved for § 1915.507(d)(5).

(xviii) NFPA 1403–2002, Standard on Live Fire Training Evolutions, IBR approved for § 1915.508(d)(8).

■ 3. Amend § 1915.505 to revise paragraph (e)(3)(v) to read as follows:

§ 1915.505 Fire response.

* * * * *

(e) * * *

(3) * * *

(v) Provide only SCBA that meet the requirements of NFPA 1981–2002 Standard on Open-Circuit Self-Contained Breathing Apparatus for Fire and Emergency Services (incorporated by reference, see § 1915.5); and

* * * * *

■ 4. Amend § 1915.507 to revise paragraphs (b)(1), (b)(2), (c)(6), (d)(1), (d)(2), (d)(3), and (d)(5) to read as follows:

§ 1915.507 Land-side fire protection system.

* * * * *

(b) * * *

(1) The employer must select, install, inspect, maintain, and test all portable fire extinguishers according to NFPA 10–2002 Standard for Portable Fire Extinguishers (incorporated by reference, see § 1915.5).

(2) The employer is permitted to use Class II or Class III hose systems, in accordance with NFPA 10–2002 (incorporated by reference, see § 1915.5), as portable fire extinguishers if the employer selects, installs, inspects, maintains, and tests those systems according to the specific recommendations in NFPA 14–2003 Standard for the Installation of Standpipe and Hose Systems (incorporated by reference, see § 1915.5).

(c) * * *

(6) Select, install, inspect, maintain, and test all automatic fire detection systems and emergency alarms according to NFPA 72–2002 National Fire Alarm Code (incorporated by reference, see § 1915.5)

(d) * * *

(1) Standpipe and hose systems according to NFPA 14–2003 Standard

for the Installation of Standpipe and Hose Systems (incorporated by reference, see § 1915.5);

(2) Automatic sprinkler systems according to NFPA 25–2002 Standard for the Inspection, Testing, and Maintenance of Water-based Fire Protection Systems, (incorporated by reference, see § 1915.5), and either (i) NFPA 13–2002 Standard for the Installation of Sprinkler Systems (incorporated by reference, see § 1915.5), or (ii) NFPA 750–2003 Standard on Water Mist Fire Protection Systems (incorporated by reference, see § 1915.5);

(3) Fixed extinguishing systems that use water or foam as the extinguishing agent according to NFPA 15–2001 Standard for Water Spray Fixed Systems for Fire Protection (incorporated by reference, see § 1915.5) and NFPA 11–2005 Standard for Low-, Medium-, and High-Expansion Foam (incorporated by reference, see § 1915.5);

* * * * *

(5) Fixed extinguishing systems using gas as the extinguishing agent according to NFPA 12–2005 Standard on Carbon Dioxide Extinguishing Systems (incorporated by reference, see § 1915.5); NFPA 12A–2004 Standard on Halon 1301 Fire Extinguishing Systems (incorporated by reference, see § 1915.5); and NFPA 2001–2004 Standard on Clean Agent Fire Extinguishing Systems (incorporated by reference, see § 1915.5).

[FR Doc. E6–17124 Filed 10–16–06; 8:45 am]

BILLING CODE 4510–26–P

